



Türkiye

Attestation of Conformity

No.: M07 07P10157 0008

Holder of Certificate: GÜNTER Klima Cihazları Ltd. Şti.
Esenboğa yolu Çankırı yol ayrımı 19. Km.
Akyurt - Ankara
TURKEY

Product: Air Handling Units

Model(s): GKS-1, GKS-2, GKS-3, GKS-4, GKS-5, GKS-6,
GKS-7, GKS-8, GKS-9, GKS-10, GKS-11, GKS-12,
GKS-13, GKS-14, GKS-15, GKS-16, GKS-17,
GKS-18, GKS-19, GKS-20, GKS-21, GKS-22,
GKS-23, GKS-24

Parameters: Rated Voltage: 400V AC
Rated Frequency: 50 Hz
Protection Class: I
Degree of Protection: IP 54

**Product Tested
And Inspected
according to:** EN ISO 12100-1:2003
EN ISO 12100-2:2003
EN 1050:1996
EN 60204-1:2006

This Attestation of Conformity is issued on a voluntary basis according to Machinery Directive 98/37/AT. It conforms that the listed equipment (not Annex IV equipment) complies with the principal protection requirements of the directive. It refers only to the particular sample and its technical documentation submitted for inspection.

Test Report No.: TGK-LTMP-07-008

Date, 2007-07-09



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 1